



## COLLECTOR

### NOTES:

1. THE BASE MAY BE OMITTED UNDER SIDEWALK IF SUBGRADE IS SANDY SOIL.
2. TYPICAL - MAY VARY 0.5% MIN. TO 2% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
3. TYPICAL - MAY VARY 1% MIN. TO 4.0% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
4. THICKNESS OF BASE REQUIRED UNDER CURB & GUTTER SHALL BE 8" ON CLAYEY SOILS AND 6" ON SANDY SOIL.
5. IF SIDEWALK IS ADJACENT TO CURB, SIDEWALK WIDTH SHALL BE 5' MINIMUM AND HAVE 4' CLEAR AROUND ANY OBSTRUCTION. ALSO SEE T108 AND T109.

### CITY OF TORRANCE - ENGINEERING DEPARTMENT

DATE ISSUED  
16 NOV 1998

### TYPICAL SECTION COLLECTOR AND ARTERIAL STREET

RICHARD W. BURTT  
ENGINEERING DIRECTOR  
R.C.E. NO. 32862

STANDARD NO.

**T103-2**

SHEET 1 OF 2

TT/T103-21